

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 1452-1200:109

Page 1 of 1

**CATEGORY:** Floor-to-Floor/Floor-to-Wall Joint Systems

**LISTEE:** Hilti, Inc., 5400 S. 122nd East Ave, Tulsa, OK 74121  
Contact: \*Jonathan W. Matthews (918) 252-6181 Fax (918) 254-1679

**DESIGN:** Type CP 672 firestop joint spray for use in floor-to-floor and floor-to-wall joint systems.  
Refer to listee's data sheet for detailed product description and operational considerations.

| <b>RATING:</b> | System No. | Assembly Rating |
|----------------|------------|-----------------|
|                | FF-D-1013  | 2 Hr.           |
|                | FW-D-1013  | 2 Hr.           |

**INSTALLATION:** In accordance with listee's printed installation instructions, UL Fire Resistance Directory, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, classification and UL label.

**APPROVAL:** Listed as firestop spray for use in floor-to-floor and floor-to-wall joint system when constructed and installed in accordance with UL Fire Resistance Directory. Approved systems:

FF-D-1013 and FW-D-1013

**NOTE:** For Head-of-Wall or Wall-to-Wall joint systems, see CSFM Category 1451.

\*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**